

Energy Efficiency: Motors and Smart Meters

Tom Nelson
National Institute of Standards and Technology
June 8, 2016




Efficiency and Greenhouse Gas Reductions

- Labeling Programs for appliances
- Efficiency standards for appliances (mandatory & voluntary)
- Regulation or incentives to replace inefficient lighting
- Regulations encouraging renewable generation
- Efficiency standards for:
 - Motors
 - Distribution Transformers

Methods for Reduction of Greenhouse Gases


- Increasing renewable energy generation
- Encouraging Electric Vehicle Usage
- Efficient Building Standards – LEED
- Energy Usage Information
- Smarter Grids
- Distributed Energy Resources

Today's Electric Grid



- *Centralized, bulk generation, mainly coal and natural gas*
- *Responsible for 40% of human-caused CO₂ production*
- *Controllable generation and predictable loads*
- *Limited automation and situational awareness*
- *Lots of customized proprietary systems*
- *Lack of customer-side data to manage and reduce energy use*

Smart Grid: The “Energy Internet”



Standards Provide a Critical Foundation

What is the Smart Grid?

The Smart Grid integrates information technology and advanced communications into the power system in order to:

- Increase system efficiency and cost effectiveness
- Provide customers tools to manage energy use
- Improve reliability, resiliency and power quality
- Enable use of innovative technologies including renewables, storage and electric vehicles




What Will the Smart Grid Look Like?

- High use of renewables – 20% – 35% by 2020
- Distributed generation and microgrids
- Bi-directional metering – selling local power into the grid
- Distributed storage
- Ubiquitous smart appliances communicating with the grid
- Energy management systems in homes as well as commercial and industrial facilities linked to the grid
- Growing use of plug-in electric vehicles
- Networked sensors and automated controls throughout the grid

Smart Meters

- Smart meters that provide near-real time usage data
- Time of use and dynamic pricing
- Distribution automation and efficiency
- Energy management systems in homes as well as commercial and industrial facilities linked to the grid
- Growing use of plug-in electric vehicles
- Phase Identification

Advanced Metering Interface -AMI



Power Usage to Personal Activity Mapping

Electric Utility Power System (Utility)

Service Drop

IEEE

National Electric Code (Enclosures)

NFPA

UL

Equipment

Branch Circuit

AC Electrical Energy

Connector

Electric Vehicle Energy Transfer System (EV-ETS)

Electric Vehicle (EV)

Inlet

Storage Battery

DC Electrical Energy

SAE J2293 (Communication)

ZigBee® Smart Energy 2.0

ANSI

NEMA

IEEE C12 (Meter)

IEEE 1547 (Distributed energy interconnection)

SAE J1772 (Connector)

ISO (Battery)

IEC

IEC 61850 and 61970/61968 Information models



NESB

OASIS

Demand response & price signaling

Consumer Electronics Can Drive Innovation on Customer Side of the Meter

NIST Smart Grid Reference Model



- Home area network
- Energy services interface
- Home energy management systems/apps
- Controllers
- Displays
- Sub-metering devices
- Embedded smart grid-aware intelligence

Energy usage information driving energy reduction

- The Green Button initiative is an industry-led effort that responds to a White House call-to-action to provide utility customers with easy and secure access to their energy usage information in a consumer-friendly and computer-friendly format. Customers are able to securely download their own detailed energy usage with a simple click of a literal "Green Button" on electric utilities' websites.


Green Button

- With their own data in hand, consumers can take advantage of a growing array of online services to help them manage energy use and save on their bills. Voluntary adoption of a consensus industry standard by utilities and companies across the country both enables and incentivizes software developers and other entrepreneurs to build innovative applications, products and services which will help consumers manage energy use by, for example, programming their home energy management devices, sizing and financing rooftop solar panels, and helping a contractor to verify their home energy savings more cost-effectively.
- Adoption of the Green Button data standard will also benefit utilities that receive numerous requests for data, are administering energy efficiency programs, are looking for avenues for greater customer engagement, and in many other ways.

Green Button


- The ESPI standard consists of two components: 1) a common XML format for energy usage information and 2) a data exchange protocol which allows for the automatic transfer of data from a utility to a third party based on customer authorization. All of the utilities that have committed to Green Button will implement the common XML data format in an easy to download manner.
- **What does Green Button data include?**
- The Green Button data standard is flexible enough to handle different types of energy data and time interval usage, and applications are being developed for both residential and commercial customers. The data can be provided in 15-minute, hourly, daily, or monthly intervals depending on what a utility decides to make available and what level of detail they are able to provide. The Green Button Initiative is not limited to utilities that have deployed smart meters that produce very detailed information about energy consumption, but also includes utilities that are able to provide only monthly billing data. The ESPI data standard can also be extended in the future to support natural gas and water usage information and other uses, and these options are being explored.
- **What is Green Button Connect My Data?**
- Many utilities are implementing *Green Button Download My Data* which means that the utility customer can download their own energy consumption data directly to their own computer, and if they so choose, upload their own data to a third party application. *Green Button Connect My Data* is a new capability which allows utility customers to automate the secure transfer their own energy usage data to authorized third parties, based on affirmative (opt-in) customer consent and control.

Power Bridge (32 years and going)




- Sinusoidal single frequency power measurement system
- Uses Voltage and resistance (at unity PF) to measure current

PJVS-Referenced Power Calibration Source



more detail...



Combining uncertainties (60 Hz)

Maximum type B uncertainty in P (active power) at any power factor

$$U_M = \pm [(\alpha_1 + \alpha_2 + \alpha_3 + \alpha_4 + \alpha_5 + \alpha_6) \cos \theta + (\beta_1 + \beta_2 + \beta_3 + \beta_4 + \beta_5 + \beta_6) \sin \theta]$$

Combined uncertainty in P (active power) at any power factor

$$U_P = [1.08 \cos^2 \theta + 1.49 \sin^2 \theta + 1.11]^{1/2}$$

U_P for several power factors (60 Hz) in ppm

0°	30°	60°	90°
1.5	1.5	1.6	1.6

NIST Sampling Power Measurement System

- NIST has constructed a waveform sampling power measurement system to measure distorted (harmonic) waveforms
- We can use several different sources to generate the distorted power waveforms
- System comprised of Voltage Attenuator, 3 stage current transformer and shunts, digital sampler, computer
- Goal of measuring power to 5 kHz at 30 ppm.

Motor Energy Usage in the U.S.

Table 1-2. Percentage of Sector Energy Use by Motor-Driven Systems (2006)

Sector	Total Electrical Energy Use for Sector, Million kWh/year ¹ , 2006	Annual Motor-Driven System Energy Use, Million kWh/year	Percentage of Sector Use by Motor-Driven Equipment	Percentage of Total Motor-Driven Equipment Energy Use
Residential	1,351,010	297,000	22.0	20.8
Commercial	1,299,443	498,000	38.3	34.9
Industrial	1,011,134	632,000	62.5	44.3

Source: U.S. Energy Information Administration, Annual Energy Review, 2010

The total annual energy consumption due to motor-driven equipment in the U.S. industrial, commercial, residential, and transportation sectors was approximately 1,431 billion kilowatt-hours (kWh) in 2006. This amounted to 38.4% of total U.S. electrical energy use

Premium Energy Efficient Motor

- Manufacturers must use increased quantities of improved materials and design motors with closer tolerances to reduce losses and allow motor designs to meet NEMA Premium Efficiency Motor Standard requirements. Typical design modifications include:
- Use of a larger wire gage to reduce stator winding resistance and minimize stator I^2R losses.
- Incorporate a longer rotor and stator to lower core losses by decreasing magnetic density while increasing cooling capacity.
- Selection of low resistance rotor bars. Larger conductor bars and end rings reduce rotor I^2R losses.
- Modification of stator slot design to decrease magnetic losses and allow for use of larger diameter wire.
- Use of a smaller fan. An efficient cooling fan design reduces airflow and power required to drive the fan.

Motor Efficiency Testing Standards

- IEEE 112, method B is called out in DOE
- IEEE 114 single phase induction motors
- IEC 60034-2-1
- CSA C390-10
- JEC-37
- BS-269

IEC Motor Standards

Field	IEC reference	Year of publication	Title	
Rating	IEC 60034-1, edition 12.0	2010	Rating and performance	Preview Buy
Testing	IEC 60034-2-1, edition 2.0	2014	Standard methods for determining losses and efficiency from tests (excluding machines for traction vehicles)	Preview Buy
Testing	IEC 60034-2-2, edition 1.0	2010	Specific methods for determining separate losses of large machines from tests - Supplement to IEC 60034-2-1	Preview Buy
Testing converter-fed motors	IEC/TS 60034-2-3, edition 1.0	2013	Specific test methods for determining losses and efficiency of converter-fed AC induction motors	Preview Buy
Efficiency classes	IEC 60034-30-1, edition 1.0	2014	Efficiency classes of line operated AC motors (IE-code)	Preview Buy
Guide	IEC 60034-31, edition 1.0	2010	Selection of energy-efficient motors including variable speed applications - Application guide	Preview Buy


Work in progress

Field	IEC reference	Title	Status
Efficiency classes	IEC 60034-30-2	Efficiency classes of variable speed AC motors	New, expected to be published in 2016/17
Converters: efficiency classes and test methods	IEC 61800-9-2	Ecodesign for power drive systems, motor starters, power electronics & their driven applications - Energy efficiency indicators for power drive systems and motor starters	New, expected to be published in 2016/17

Motor Testing

- IEEE Std 112B, IEC 60034-2-1, CSA C390-10 give similar results
- Decide on a standard to use for testing
- Study on repeatability of IEEE 112B concluded results would be repeatable to about 0.5%.

DOE Premium Motor Selection and Application Guide



Motors

- When annual operating hours are above 2,000 hours per year, electric motors are extremely energy intensive. This explains why a seemingly small 2% to 3% improvement in energy efficiency can lead to significant annual energy and dollar savings.

DOE Efficiency Motor Software

- MotorMaster+ and MotorMaster International are available in the AMO Energy Resources Center at www.manufacturing.energy.gov.
- To help you identify, evaluate, and procure premium efficiency motors, AMO developed and maintains the MotorMaster+ software tool. MotorMaster+ is a free motor selection and management tool that supports energy management and motor system improvement planning by identifying the most efficient choice for a given repair or motor purchase decision. The tool includes a catalog of more than 20,000 low-voltage induction motors and features motor inventory management tools, maintenance log tracking, efficiency analysis, savings evaluation, energy accounting, and environmental reporting capabilities.



United States Department of Commerce
Technology Administration
National Institute of Standards and Technology

www.nist.gov

NIST Technical Note 1422

***Electric Motor Efficiency Testing Under
the New Part 431 of Chapter II of Title 10,
Code of Federal Regulations: Enforcement Testing***

K. L. Stricklett and M. Vangel

NIST Technical Note 1432

***Test Procedures for Electric Motors Under 10 CFR
Part 431***

K. L. Stricklett and M. Vangel

NIST Technical Note 1427

***An Analysis of Efficiency Testing Under the Energy
Policy and Conservation Act: A Case Study With
Application to Distribution Transformers***

K. L. Stricklett, M. Vangel, and O. Petersons



IEEE Standard Definitions for the Measurement of Electric Power Quantities Under Sinusoidal, Nonsinusoidal, Balanced, or Unbalanced Conditions

IEEE Power & Energy Society

Sponsored by the
Power System Instrumentation and Measurements Committee

IEEE
3 Park Avenue
New York, NY 10016-5997, USA
19 March 2010

IEEE Std 1459™-2010
(Revision of
IEEE Std 1459-2000)

1459™

Sample of Publications on IEEE 1459

IEEE TRANSACTIONS ON POWER DELIVERY, VOL. 26, NO. 2, APRIL 2011

Discussion on Useless Active and Reactive Powers Contained in the IEEE Standard 1459

A Smarter Meter: IEEE-1459 Power Definitions in an Off-the-Shelf Smart Meter

Salvador Orts-Grau, *Member, IEEE*, Nicolás Muñoz-Galeano, José Carlos Alfonso-Gil, Francisco J. Gimeno-Sales, and Salvador Seguí-Chilet, *Member, IEEE*

Andrew J Berrisford, *Member, IEEE*

IEEE TRANSACTIONS ON POWER DELIVERY, VOL. 26, NO. 3, JULY 2011

IEEE TRANSACTIONS ON POWER DELIVERY, VOL. 30, NO. 3, JUNE 2015

Time-Frequency-Based Instantaneous Power Components for Transient Disturbances According to IEEE Standard 1459

Moinul Islam, *Student Member, IEEE*, Hossein Ali Mohammadpour, *Student Member, IEEE*, Amin Ghaderi, *Student Member, IEEE*, Charles W. Brice, *Senior Member, IEEE*, and Yong-June Shin, *Senior Member, IEEE*

Comprehensive Definitions for Evaluating Harmonic Distortion and Unbalanced Conditions in Threeand Four-Wire Three-Phase Systems Based on IEEE Standard 1459

Sobhan Mohamadian, *Student Member, IEEE*, and Abbas Shoulaie

Where is the power of the IEEE 1459-2010?

Johan Rens

School for Electrical and Electronic Engineering
Potchefstroom Campus of the North-West University
Potchefstroom, South Africa


johan.rens@nwu.ac.za

Tian van Rooyen, Francois de Jager
School for Electrical and Electronic Engineering
Potchefstroom Campus of the North-West Univ

- Measurement time matters
- Measurement algorithm matters

Incandescent Bulb

63.2 W, 1.0 PF




CFL Bulb

47.2 W, 0.59 PF





LED Bulb


10.4 W, 0.81 PF



LED Bulb #2









Monitor Standby


0.9 W, 0.22 PF



Laptop Power Supply



Harmonic Waveform Tests in Draft C12.20 Standard




Condition	Voltage Waveform	Current Waveform	Maximum Deviation in Percent from Reference Performance		
			Accuracy Class		
			0.5	0.2	0.1
(1)	V_{ref} Sinusoidal	I_{ref} Sinusoidal	Reference	Reference	Reference
(2)	V_{ref} Sinusoidal	90 Degree Phase Fired Waveform	$\pm 0.5\%$	$\pm 0.3\%$	$\pm 0.2\%$


Harmonic Waveform Tests in Draft C12.20 Standard

Harmonic	Voltage Amplitude % V_{ref}	Phase	Current Amplitude % I_{ref}	Phase	Energy
1	100	0	100	0	100.000
3	3.8	180	30	0	-1.140
5	2.4	180	18	0	-0.432
7	1.7	180	14	0	-0.238
11	1.1	180	9	0	-0.099
13	0.8	180	5	0	-0.040
Total Energy					98.051

Voltage



Current



Condition	Voltage Waveform	Current Waveform	Maximum Deviation in Percent from Reference Performance		
			Accuracy Class		
(1)	V_{ref} Sinusoidal	I_{ref} Sinusoidal	0.5 Reference	0.2 Reference	0.1 Reference
(2)	V_{ref} Sinusoidal	Quardiform Current Waveform	±0.5%	±0.3%	±0.2%
(3)	Quardiform Voltage Waveform	Quardiform Current Waveform	±0.8%	±0.5%	±0.3%





Harmonic Waveform Tests in Draft C12.20 Standard

Harmonic	Voltage Amplitude % V_{ref}	Phase	Current Amplitude % I_{ref}	Phase	Energy
1	100	0	100	0	100.00
3	3.8	0	30	180	-1.140
5	2.4	180	18	0	-0.432
7	1.7	0	14	180	-0.238
11	1.1	0	9	180	-0.099
13	0.8	180	5	0	-0.040
Total Energy					98.051



Voltage

Current



Condition	Voltage Waveform	Current Waveform	Maximum Deviation in Percent from Reference Performance		
			Accuracy Class		
			0.5	0.2	0.1
(1)	V_{ref} Sinusoidal	I_{ref} Sinusoidal	Reference	Reference	Reference
(2)	V_{ref} Sinusoidal	Peaked Current Waveform	±0.5%	±0.3%	±0.2%
(3)	Peaked Voltage Waveform	Peaked Current Waveform	±0.8%	±0.5%	±0.3%


Harmonic Waveform Tests in Draft C12.20 Standard



Harmonic	Voltage Amplitude % V_{ref}	Phase	Current Amplitude % I_{ref}	Phase	Energy
1	100	0	100	0	100.000
3	3.8	0	80	180	-3.040
5	2.4	180	60	0	-1.440
7	1.7	0	40	180	-0.680
9	1.5	180	22	0	-0.330
11	1.1	0	12	180	-0.132
13	0.8	180	5	0	-0.040
15	0.6	0	2	180	-0.012
17	0.4	180	1	0	-0.004
19	0.3	0	0.5	180	-0.0015
Total Energy					94.321

Condition	Voltage Waveform	Current Waveform	Maximum Deviation in Percent from Reference Performance		
			Accuracy Class		
			0.5	0.2	0.1
(1)	V_{ref} Sinusoidal	I_{ref} Sinusoidal	Reference	Reference	Reference
(2)	V_{ref} Sinusoidal	Pulse Current Waveform	±0.5%	±0.3%	±0.2%
(3)	Pulse Voltage Waveform	Pulse Current Waveform	±0.8%	±0.5%	±0.3%


Harmonic Waveform Tests in Draft C12.20 Standard



Harmonic	Voltage Amplitude % V_{ref}	Phase	Current Amplitude % I_{ref}	Phase	Energy
1	100	0	100	0	100.000
2	0	0	5 ± 1	90 ± 2	0
3	0	0	18 ± 2	-160 ± 2	0
4	0	0	10 ± 2	110 ± 2	0
5	0	0	66 ± 3	130 ± 2	0
7	0	0	50 ± 3	50 ± 2	0

Condition	Voltage Waveform	Current Waveform	Maximum Deviation in Percent from Reference Performance		
			Accuracy Class		
			0.5	0.2	0.1
(1)	V_{ref} Sinusoidal	I_{ref} Sinusoidal	Reference	Reference	Reference
(2)	V_{ref} Sinusoidal	MZC Current Waveform	$\pm 0.5\%$	$\pm 0.3\%$	$\pm 0.2\%$

Harmonic Waveform Tests in Draft C12.20 Standard



Harmonic	Voltage Amplitude % V_{ref}	Phase	Current Amplitude % I_{ref}	Phase	Energy
1	100	0	100	0	100.000
3	0	0	0	0	0
5	20 ± 2	155 ± 5	0	0	0
7	25 ± 4	155 ± 5	0	0	0

Condition	Voltage Waveform	Current Waveform	Maximum Deviation in Percent from Reference Performance		
			Accuracy Class		
			0.5	0.2	0.1
(1)	V_{ref} Sinusoidal	I_{ref} Sinusoidal	Reference	Reference	Reference
(2)	MZC Voltage Waveform	I_{ref} Sinusoidal	$\pm 0.5\%$	$\pm 0.3\%$	$\pm 0.2\%$

Measurement Canada Developments

- In October 2005, MC established the Volt-Ampere Joint Working Group (VA JWG) comprised of MC and electricity industry representatives with a mandate to identify and study the factors that contribute to inequity in the measurement of apparent energy and demand, and to make recommendations that would aim to minimize or eliminate the inequities found. Harmonic content was one of multiple factors identified and assessed.

- Thank you for your attention
- Contact: thomas.nelson@nist.gov



rad

Hz

α

Algorithm Information is Critical

- Know what you are measuring
- What are you going to do with the data, what applications are you going to use, what are the application requirements (uncert., bandwidth, time,) all these are important
- If measurements from one instrument are used by another, does it need to know information about the number it is using? If it is a voltage measurement, is it rms/peak...that's typically easy, but what about meas. Uncert, samples per cycle, number of cycles, bandwidth,...

What's a Watt?

- Watt IEEE Std 100 defines it to be power required to do work at rate of 1 Joule/Second
- Draft C12 VA standard defines watt to be:

Active power: The integral of the instantaneous voltage (V) times the instantaneous current (I) over precisely one cycle of the voltage waveform.

$$P = \frac{1}{T} \int_0^T V(t)I(t)dt$$

Where T is the period of the voltage waveform.

- Var
- VA
- Harmonics
- Interharmonics
- Sub Harmonics

Excerpt from IEEE 1459

Table 1—Summary and grouping of the quantities in single-phase systems with nonsinusoidal waveforms

Quantity or indicator	Combined	Fundamental powers	Nonfundamental powers
Apparent	S (VA)	S_1 (VA)	S_N S_H (VA)
Active	P (W)	P_1 (W)	P_H (W)
Nonactive	N (var)	Q_1 (var)	D_I D_V D_H (var)
Line utilization	$PF = P/S$	$PF_1 = P_1/S_1$	—
Harmonic pollution	—	—	S_N/S_1

IEEE Recommended Practices in Power Quality

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

IEEE Power and Energy Society

Sponsored by the
Transmission and Distribution Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std 519™-2014
(Revision of
IEEE Std 519-1992)



IEEE Recommended Practice for Monitoring Electric Power Quality

IEEE Power & Energy Society

Sponsored by the
Transmission and Distribution Committee

1159™

IEEE
3 Park Avenue
New York, NY 10016-5997, USA
26 June 2009

IEEE Std 1159™-2009
(Revision of
IEEE Std 1159-1995)

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems IEEE 519

- **harmonic (component):** A component of order greater than one of the Fourier series of a periodic quantity. For example, in a 60 Hz system, the harmonic order 3, also known as the “third harmonic,” is 180 Hz.
- **interharmonic (component):** A frequency component of a periodic quantity that is not an integer multiple of the frequency at which the supply system is operating (e.g., 50 Hz or 60 Hz).
- The width of the measurement window used by digital instruments employing Discrete Fourier Transform techniques should be 12 cycles (approximately 200 ms) for 60 Hz power systems
- Very short time harmonic values are assessed over a 3-second interval based on an aggregation of 15 consecutive 12 (10) cycle windows for 60 (50) Hz power systems.
- Short time harmonic values are assessed over a 10-minute interval based on an aggregation of 200 consecutive very short time values for a specific frequency component.
- Very short and short time harmonic values should be accumulated over periods of one day and one week, respectively. For very short time harmonic measurements, the 99th percentile value (i.e., the value that is exceeded for 1% of the measurement period) should be calculated for each 24-hour period for comparison with the recommend limits in Clause 5. For short time harmonic measurements, the 95th and 99th percentile values (i.e., those values that are exceeded for 5% and 1% of the measurement period) should be calculated for each 7-day period for comparison with the recommended limits in Clause 5. These statistics should be used for both voltage and current harmonics with the exception that the 99th percentile short time value is not recommended for use with voltage harmonics.

Communication Standards

- ANSI C12.19
- DLMS/COSEM
- IEC 61850
- DNP3
- Others
- Communications between field devices
- I want to hear your thoughts on what you think would be a good metering/sensor protocol 10 years from now

Metering not under PUC Jurisdiction

- EV Charging - Commercial transactions covered by Weights and Measures
- Measurement testing procedures are being developed for EV chargers
- Type evaluation program is starting for accuracy testing of EV chargers
- Test equipment is being developed for field inspectors
- Submetering topic is getting underway

Semantics

- THD and different definitions of it
- Voltage (did they mean $V_{\text{peak to peak}}$, V_{peak} , V_{rms} ? Different “communities” use what is normal for their expertise and may assume you know what they mean and vice-versa

Measurement Canada Developments

- Recommendations of the VA JWG resulted in draft specifications that were provided for public consultation in early 2012. Following this consultation, MC established the Complex Measurement Implementation (CMI) JWG, which was mandated to consider new information and related measurement issues, address certain concerns raised by the industry and conclude on revisions to the draft specifications. At that time the draft specifications were contemplating various approaches to inclusion of harmonic content within a given LUM value. The CMI considered various factors in light of the IEEE's discontinuation of the Budeanu var determination methodology.

Measurement Canada Developments

- MC and Canadian industry stakeholders (through the Canadian Electricity Association) have acknowledged that a measurement approach utilizing RMS values for LUMs does so without consideration of the directionality of the harmonic content. In other words, there is no manner to determine which party to a trade transaction is sinking or sourcing harmonic content, and thus the resulting LUM values may not equitably represent the actual trade of the electricity commodity.

Measurement Canada Developments

- Electricity sellers (generators and utilities) are in the business of selling a commodity; they provide the components of energy that are used by various consumer (purchaser) appliances via voltage and current in fundamental form. These parties do not generate, nor purport to sell harmonic content, yet RMS metering would in fact establish values of LUM that include harmonic content. The result is further inequity as the seller is recouping costs via their price per unit LUM for a product that they are not actually providing or selling.
- A foundational reason for using measurement of watt and var (measuring var directly) for establishing VA values is that both watt and var measurement (in absence of harmonics) can be defined consistently in AC single phase and AC polyphase environments. Watts are always along the X-axis and vars are always along the Y-axis, there is consistency and the var definition is complementary to that of the watt definition. VA on the other hand can be all over the 360 range of 4 quadrants, and while it can be consistently defined in DC, and AC single phase environment, its definition in the polyphase environment is more ambiguous. Hence from a legal metrology perspective VA should be derived from watts and vars


Measurement Canada Developments

- A key facet of MC approach to equity is that individual LUM values for energy be clearly distinguished by directionality; these values must be independently identified, assessed and attributed to the correct party (seller or purchaser). How a seller decides to use such values in the price per unit of the trade transaction is up to them, but from the perspective of the legislation in Canada, the information must be provided in an accurate, standard, and transparent manner.

Measurement


- The following 9 slides are courtesy of Andrew Berrisford from BC Hydro
- Andrew has spent many years working with measurements of harmonic power
- andrew.berrisford@bchydro.com

Harmonic Power Flow Inequity



Sinusoidal Conditions
No inequity due to harmonics


Harmonic Power Flow Inequity



Harmonic Power Flow Inequity


Utility source Z absorbs 5 W of harmonic
Power sourced from nonlinear load

linear load absorbs 5 W of harmonic
Power sourced from nonlinear load




Harmonic Power Flow Inequity

P meter adds harmonic power for linear load effectively applying a penalty




Harmonic Power Flow Inequity

Replace meter with a model
That registers 67% of P_H



Harmonic VA Inequity

P meter adds harmonic power for linear load effectively applying a penalty. The harmonic power is included in the VA rms measurement



P subtracts harmonic power from nonlinear load effectively giving it a discount. The harmonic power is included in the VA rms measurement

Types of Inequity

b) *Apparent Power Demand Inequity.*

Different meters applying different definitions or methods for S. This results in inequities:


- a) Between consumers on the same rate but with meters that apply different methods.
- b) A consumer that gets a meter replaced by another that applies a different method.

Prototype HIP P_1/P Comparison

Prototype HIP Meters installed at four residential consumers for a year. These sites have insignificant harmonic distortion levels.

$P_1 < P$ for 1 site

$P_1 > P$ for 3 sites



Excerpt from Andrew Berrisford BC Hydro

Meter D_V (Voltage Distortion Power) and D_I (Current Distortion Power)

Calculate Ratio $HF = D_I/D_V$ (similar to $PF = P/S$)

If this ratio is one or lower, the consumer is unlikely to be a Significant source of harmonics.

If the ratio is greater than one, the consumer is likely a generator of Harmonics. Apply Penalties like PF penalties, eg:

$HF \leq 1.1$: No HF Penalty
 $HF > 1.1$ but ≤ 1.2 : 1% HF Penalty
 $HF > 1.2$ but ≤ 1.4 : 2% HF Penalty
 $HF > 1.4$ but ≤ 1.6 : 5% HF Penalty

This ratio does not penalise consumer for absorbing harmonics due To background voltage distortion

Electricity Meters

- What will be possible if 1% of meters were sending voltage and current readings every 5 seconds, how about 10% of the meters on the system?
- How well could meters be time synchronized on a feeder? What would that enable?
- Have any utilities looked into using success of IoT implementation at factories dramatic improvements for justifications for sensors in the grid?

Uncalibrated Data from Devices

- Light bulbs, incandescent, CFL, LED, LED desk lamp, power supply
- Laptop computer
- Computer monitor
- Fan
- Soldering iron

PF Measurements

Device	Watts	Power Factor
Incandescent light bulb	63.2	1.00
CFL	47.2	0.59
LED	10.4	0.81
LED	10.1	0.95
LED desk lamp	5.8	0.54
Fan	42	0.93
Laptop computer	23	0.51
PC Monitor	147.5	0.99
PC Monitor	0.9	0.22
Small power supply	34.1	0.74

Harmonics in IEC small appliances

- Some appliance manufacturers are incorporating PFC into their finished products. The European Union's International Electro-Technical Commission adopted the IEC61000-3-2 standard that required, by Jan. 1, 2001, all equipment needing 75 W of power or greater and less than 16 A to meet standards for harmonic generation and, thus, meet PFC requirements. Thereafter, Britain, China and Japan adopted similar standards.
- North America does not presently have these requirements.

Distributed Renewable Generation


- Distribution scale variable generation (solar, wind) DER
- Duck Curve
- Loads “hidden” by DER
- Possible DC bus in the home?

Transactive Energy

- The term "transactive energy" is used here to refer to techniques for managing the generation, consumption or flow of electric power within an electric power system through the use of economic or market based constructs while considering grid reliability constraints. The term "transactive" comes from considering that decisions are made based on a value. These decisions may be analogous to or literally economic transactions. An example of an application of a transactive energy technique is the double auction market used to control responsive demand side assets in the GridWise Olympic Peninsula Project¹. Another would be the TeMix work of Ed Cazalet². Transactive energy techniques may be localized to managing a specific part of the power system, for example, residential demand response. They may also be proposed for managing activity within the electric power system from end-to-end (generation to consumption) such as the transactive control technique being developed for the Pacific Northwest Smart Grid Demonstration project^{3,4}. An extreme example would be a literal implementation of "prices-to-devices" in which appliances respond to a real-time price signal.
- The current situation is that dynamic pricing is widely used in the wholesale power markets. Balancing authorities and others operations such as hydro desks routinely trade on the spot market to buy or sell power for very near term needs. In addition, dynamic pricing tariffs are being tried in a number of retail markets, for example, the PowerCentsDC dynamic pricing pilot⁵.

Phasor and SynchroPhasor

- A Phasor is the complex form of an AC waveform (magnitude with a phase)
- GPS used to Reference All Grid Phasors to UTC
- SynchroPhasor standard IEEE C37.118



Points to Consider


- Measurement time can give different results depending on the waveforms
- Measurement algorithm can give different results depending on the waveforms
- Application may have assumptions about the algorithm and measurement time that are incorrect

What about automatic grid control?

- Algorithm differences may cause more issues if you are using output of meter (sensor) used by automated grid control and the assumptions the controller has about the data coming into it

Standards Come From Many Sources

International



I E T F[®]



SAE *International*[™]

Global
Consortia



OGC[®]
Open Geospatial Consortium, Inc.

OASIS 

Regional and
National



American National Standards Institute




NEMA

Physical Measurement Laboratory




Post-EISA Efficiency Trend 2008-2013




Regulatory forecast model 1 to 200 hp


Bifilar shunt design




Bifilar shunt circuit model




How do we generate and measure V , I , θ ?



Agreement between PJVS-referenced signal generation and a thermal transfer standard (TTS)



Permuting capacitance measurements of V_V / V_I ratios and voltage amplifier gain/phase.





Current circuit

- Current transducer based on a $0.1\ \Omega$ shunt
- Bifilar shunt (based on Laug, Souders (NIST) design)
- AC characteristics known
- Temperature-controlled ($< 1\ \mu\Omega/\Omega$ from $0.1 - 10\ \text{A}$)
- Long term stability of better than $0.2\ \mu\Omega/\Omega$ /year (traceable to the QHR)
- 3-Stage, amplifier-aided, 1:1 voltage transformer (based on Miljanic, So, Moore (NRC) design) to reject the common-mode voltage at the shunt output (negligible error contribution, determined in-situ)


Direct sampling vs. differential sampling

V_V / V_I ratio



Bifilar shunt frequency response

Resistance Change: (M1_R15)



Phase Angle: (M1_R15)

